



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126TRL45213

Issued Date : 28-07-2026

Organization Type : Educational Institutions

Expiry Date : 27-07-2027

Name of the Organization : VIDYA MANDIR SCHOOL

Address : THADAPERUMBAKKAM PONNERI

I, HEMAMALINI G owner/manager of the VIDYA MANDIR SCHOOL functioning as Educational Institutions located at Thadaperumbakkam 1 in Tiruvallur district hereby declare that

- This Self-Declared Sanitation certificate is valid from 28-07-2026 to 27-07-2027 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 444 people/pupils and has 40 urinals and 20 toilets which is proportionate to the number of users as per government norms.
- 20 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.



Signature of the Owner/Manager



(அ) TN00126TRL45213 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பार्சுகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126TRL45213 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.



TEST WATER BEFORE TASTE

TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

District Level Water Testing Laboratory

TWAD Board. No. 6/24, Lalbhagadur Sasthiri St, Periakuppam, Thiruvallur - 602 001

TEST REPORT

Ph : 044-27663937

From

Mr.T.P.Sampath Kumar,

The Assistant Executive Engineer ,

TWAD Board,

RWS Sub Division,

Gummidipoondi.

Lr. No. 29742/AEE/TWAD/DWTL/TVR/Dt. 09.03.2026

To

Mrs.Hemamalini.G,M.A.,B.Ed.,

Correspondent,

Vidya Mandir School,

Thadaperumbakkam,

Ponneri - 601 204.

Ref : 1.Your Lr.No.Nil/Dated: 03.03.2026

2.T.O.Invoice No.29616/Dated. 04.03.2026 for 1180/-

'The result of analysis for the water samples sent under reference is enclosed'

Source: RO

Location : Thadaperumbakkam (School Campus)

Date of Collection : 03.03.2026

Date of Receipt : 03.03.2026

BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	Result
I. PHYSICAL EXAMINATION.			29742
1. Appearance	-	-	Clean & Clear
2. Colour	5	15	
3. Odour	Agreeable	Agreeable	Agreeable
4. Turbidity NT Units	1	5	0.0
5. Total dissolved Solids mg/L	500	2000	116
6. Electrical Conductivity Micro mho/cm	-	-	110
II.CHEMICAL EXAMINATION:			
7. pH	6.5-8.5	6.5-8.5	7.18
8. Ph. Alkalinity as CaCO ₃ mg/L	-	-	-
9. Total Alkalinity. as CaCO ₃ mg/L	200	600	44
10. Total Hardness as CaCO ₃ mg/L	200	600	64
11. Calcium as Ca mg/L	75	200	13
12. Magnesium as Mg mg/L	30	100	8
13. Sodium as Na mg/L	-	-	-
14. Potassium as K mg/L	-	-	-
15. Iron as Fe mg/L	0.3	0.3	0.00
16. Manganese mg/L	0.1	0.3	-
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0.0
18. Nitrite as NO ₂ mg/L	-	-	-
19. Nitrate as NO ₃ mg/L	45	45	0
20. Chloride as Cl mg/L	250	1000	30
21. Fluoride as F mg/L	1.0	1.5	0.0
22. Sulphate as SO ₄ mg/L	200	400	0
23. Phosphate as PO ₄ mg/L	-	-	-
24. Tidy's Test 4 hrs.as O ₂ mg/L	-	-	-
25. Residual chloride	0	1	0.0

Report: 29742 : The given water sample is Chemically Potable.

T.P. Sampath Kumar
13.3.26
Assistant Executive Engineer
TWAD Board, RWS Sub Division
Gummidipoondi